

## Certificate of Registration

**Certificate Number 022**

Placed on the Market under the Name of

**ADCAS (1997) Ltd  
Unit 12a, Park View Road West  
Park View Industrial Estate  
Hartlepool  
Cleveland  
TS25 1PG  
United Kingdom**

and produced in the manufacturing plant  
**ADCAS (1997) Ltd, Unit 12a, Park View Road West, Park View Industrial Estate, Hartlepool,  
Cleveland, TS25 1PG, United Kingdom**

This certificate attests that all provisions have been met concerning the BM TRADA requirements of the scheme:

**Q-Mark Timber Fire Door Manufacture**



Date of Initial Certification: **12/12/2000**

Date of Last Issue: **14/04/2026**

Date of Expiry: **11/12/2027**

**Natasha Bambridge  
(Divisional Director)**  
For and on behalf of Element

## Scope of Certification

### Primary Field of Application (FoA) Reports (owned by this certified company)

Either used in isolation, or can be used in conjunction with an appropriate associated document for this company, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely

| Type  | FoA Report | Rev | Owned by Certified Company named on this scope | Doorset Description | Integrity Period | FoA Standard |
|-------|------------|-----|------------------------------------------------|---------------------|------------------|--------------|
| Fire  | -          | -   | -                                              | -                   | -                | -            |
| Smoke | -          | -   | -                                              | -                   | -                | -            |
| Fire  | -          | -   | -                                              | -                   | -                | -            |
| Smoke | -          | -   | -                                              | -                   | -                | -            |

### Primary Field of Application (FoA) Reports (owned by and cascaded by a System Supplier)

The revision status of each FoA can be verified on the BM TRADA website under each System Supplier's certification entry. They are either used in isolation, or can be used in conjunction with an appropriate associated document for this company, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

| Type  | FoA Report     | System Supplier owner of Assessment Report | Doorset Description                                                                                                                                    | Integrity Period | FoA Standard |
|-------|----------------|--------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------|------------------|--------------|
| Fire  | Chilt/A01204   | Halspan Limited                            | Optima 30 Part 1 Timber (Glazed or Unglazed)                                                                                                           | 30min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | Chilt/A01205   | Halspan Limited                            | Optima 60 Part 1 Timber (Glazed or unglazed)                                                                                                           | 60min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | FEA/F97174     | Halspan Limited                            | Prima 30 Part 1 Timber (Glazed or Unglazed)                                                                                                            | 30min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | FEA/F96103     | Halspan Limited                            | Prima 60 Part 1 Timber (Glazed or Unglazed)                                                                                                            | 60min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | FEA/F97097     | Halspan Limited                            | Optima and Prima 30 Panelled (Glazed or Unglazed)                                                                                                      | 30min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | Chilt/A13242   | Halspan Limited                            | Halspan XT30 and IT30 30 minute fire resisting doorsets (Glazed or Unglazed)                                                                           | 30min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | Chilt/A13227   | Halspan Limited                            | Halspan XT60, IT60, XT60 Head Rail and XT60R 60 minute fire resisting doorsets (Glazed or Unglazed)                                                    | 60min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | Chilt/A01015   | Halspan Limited                            | Prima 60 Panelled (Glazed or Unglazed)                                                                                                                 | 60min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | BMT/CNA/F15082 | Halspan Limited                            | Halspan 120 (Unglazed)                                                                                                                                 | 120min           | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | FEA/F98164     | Pacific Rim Wood Ltd                       | The Flamebreak Range of Doorsets Using Timber Based Door Blanks in Timber Based Door Frames for 30 minutes Fire Resistance (Glazed or Unglazed)        | 30min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | FEA/F02141     | Pacific Rim Wood Ltd                       | Flamebreak 660 Ply Faced and FF660 MDF Faced Doorset Ranges in Timber Based Door Frames for 60 minutes Fire Resistance (Glazed or Unglazed)            | 60min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | Chilt/A02066   | Falcon Timber Limited                      | STREbord® 44 door assemblies for 30 Minutes Fire Resistance (STREbord® 44 blank only) (Glazed or Unglazed)                                             | 30min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | Chilt/A02066   | Falcon Timber Limited                      | STREbord® 54 door assemblies for 30 Minutes Fire Resistance (STREbord® 44 blank only) (Glazed or Unglazed)                                             | 30min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | Chilt/A02067   | Falcon Timber Limited                      | STREbord® 54 doorsets for 60 Minutes Fire Resistance (Glazed or Unglazed)                                                                              | 60min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | Chilt/A10152   | Falcon Timber Limited                      | STREbord® 54 Panelled Range of Doorsets using STREbord® 54 Panelled Door Blanks in Timber Based Door Frames 60 Minutes Fire Resistance (Unglazed only) | 60min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | BMT/CNA/F15159 | Falcon Timber Limited                      | STREdor® 44 doorsets for 30 Minutes Fire Resistance (Glazed or Unglazed)                                                                               | 30min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | WF377027       | Falcon Timber Limited                      | STREdor® 54 Doorsets for 30 Minutes Fire Resistance (Glazed or Unglazed)                                                                               | 30min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | WF377027       | Falcon Timber Limited                      | STREdor® 54 Doorsets for 60 Minutes Fire Resistance (Glazed or Unglazed)                                                                               | 60min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | Chilt/A12137   | Falcon Timber Limited                      | STREbord® 35 doorsets for 30 Minutes Fire Resistance (Glazed or Unglazed)                                                                              | 30min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | WF407090       | Falcon Timber Limited                      | STREbord® 44 doorsets for 30 Minutes Fire Resistance (Front Entrance Doorsets) (Glazed or Unglazed)                                                    | 30min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | WF407090       | Falcon Timber Limited                      | STREbord® 44 doorsets for 30 Minutes Fire Resistance (Front Entrance Doorsets) (Glazed or Unglazed)                                                    | 30min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | WF407090       | Falcon Timber Limited                      | STredor® 44 30 minute Front Entrance Doorsets (Glazed or Unglazed)                                                                                     | 30min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |
| Fire  | WF407090       | Falcon Timber Limited                      | STREdor® 54 doorsets for 30 Minutes Fire Resistance (Front Entrance Doorsets) (Glazed or Unglazed)                                                     | 30min            | BS 476 Pt22  |
| Smoke | N/A            | -                                          |                                                                                                                                                        |                  | N/A          |

|       |                |                       |                                                                                                                                  |       |               |
|-------|----------------|-----------------------|----------------------------------------------------------------------------------------------------------------------------------|-------|---------------|
| Fire  | WF427764       | Falcon Timber Limited | STREbord® 54 Fire Resisting Doorsets for 60 minutes fire resistance (Front Entrance Doorsets) (Glazed or Unglazed)               | 60min | BS 476 Pt22   |
| Smoke | N/A            | -                     |                                                                                                                                  |       | N/A           |
| Fire  | WF427764       | Falcon Timber Limited | STREdor® 54 Fire Resisting Doorsets for 60 minutes fire resistance (Front Entrance Doorsets) (Glazed or Unglazed)                | 60min | BS 476 Pt22   |
| Smoke | N/A            | -                     |                                                                                                                                  |       | N/A           |
| Fire  | WF428387       | Falcon Timber Limited | STREdor® 44 E30 FED, 30 Minute (Integrity) Fire Resisting and Smoke Control Doorsets (EXAP) (Glazed or Unglazed)                 | 30min | EN 1634-1     |
| Smoke | WF428364       | -                     |                                                                                                                                  |       | EN 1634-3     |
| Fire  | WF428388       | Falcon Timber Limited | STREdor® 44 EI30 FED, 30 Minute (Integrity and insulation) Fire Resisting and Smoke Control Doorsets (EXAP) (Glazed or Unglazed) | 30min | EN 1634-1     |
| Smoke | WF428364       | -                     |                                                                                                                                  |       | EN 1634-3     |
| Fire  | Chilt/A13058   | Moralt AG             | LAMINESSE FireSmoke Only 44/54mm (Glazed or Unglazed)                                                                            | 30min | BS 476 Pt22   |
| Smoke | N/A            | -                     |                                                                                                                                  |       | N/A           |
| Fire  | Chilt/A13059   | Moralt AG             | LAMINESSE FireSmoke 54mm Only (Glazed or Unglazed)                                                                               | 60min | BS 476 Pt22   |
| Smoke | N/A            | -                     |                                                                                                                                  |       | N/A           |
| Fire  | BMT/CNA/F14274 | Moralt AG             | LAMINESSE FireSound 44mm (Glazed or Unglazed)                                                                                    | 30min | BS 476 Pt22   |
| Smoke | N/A            | -                     |                                                                                                                                  |       | N/A           |
| Fire  | WF409922       | Moralt AG             | LAMINESSE FireSound 54mm (Glazed or Unglazed)                                                                                    | 30min | BS 476 Pt22   |
| Smoke | N/A            | -                     |                                                                                                                                  |       | N/A           |
| Fire  | WF409922       | Moralt AG             | LAMINESSE FireSound 54mm (Glazed or Unglazed)                                                                                    | 60min | BS 476 Pt22   |
| Smoke | N/A            | -                     |                                                                                                                                  |       | N/A           |
| Fire  | WF409922       | Moralt AG             | LAMINESSE FireSound 59mm (Glazed or Unglazed)                                                                                    | 30min | BS 476 Pt22   |
| Smoke | N/A            | -                     |                                                                                                                                  |       | N/A           |
| Fire  | WF409922       | Moralt AG             | LAMINESSE FireSound 59mm (Glazed or Unglazed)                                                                                    | 60min | BS 476 Pt22   |
| Smoke | N/A            | -                     |                                                                                                                                  |       | N/A           |
| Fire  | WF409922       | Moralt AG             | LAMINESSE FireSoundPlus 54 (Glazed and Unglazed)                                                                                 | 30min | BS 476 Pt22   |
| Smoke | N/A            | -                     |                                                                                                                                  |       | N/A           |
| Fire  | WF409922       | Moralt AG             | LAMINESSE FireSoundPlus 54 (Glazed and Unglazed)                                                                                 | 60min | BS 476 Pt22   |
| Smoke | N/A            | -                     |                                                                                                                                  |       | N/A           |
| Fire  | WF553321 Iss 1 | Winkhaus UK Ltd       | Winkhaus Timber Frame with Halspan Blank (Door leaf Only)                                                                        | 30min | BS 476 Pt22   |
| Smoke | WF553321 Iss 1 | -                     |                                                                                                                                  |       | BS 476Pt 31.1 |

#### Test Reports

Test reports cannot be used in conjunction with any primary FoA reports, other test reports or associated documents. They must be followed precisely without any deviation whatsoever.

No specification or parameter changes are allowed at all from that stated within the test report such as size, shape, design, glazing, leaf/frame specification, hardware etc.

| Type      | Test Report | Owner of Test Report | Doorset Description | Integrity Period | Test Standard |
|-----------|-------------|----------------------|---------------------|------------------|---------------|
| Fire only | -           | -                    | -                   | -                | -             |